

PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE

CMD Pat Testing
9, Middlefield, Pelton, DH2 1DP
Tel: 07861 688 388

Certificate Reference Number :210119candykids

DETAILS OF CLIENT/LANDLORD

Client/
Address:

Candy Kids. 83 Linghome, Chester-le-Street. DH2 2TR

TEST EQUIPMENT DETAILS

Test Equipment used

UNI-T UT528 (calibrated 13/4/18)

Serial Number

814021237

Tested by

ChrisDye - CMD Pat Testing

Date

21/1/19

Retest Date

21/1/20

ID Number	Description	Location	Class	Visual	Earth (Ω)	Insulation resistance	Leakage (mA)	Result
1	RCF Speaker	Mobile	1	PASS	0.18	>19.9 M Ω	0.57	PASS
2	RCF Speaker	Mobile	1	PASS	0.28	>19.9 M Ω	0.60	PASS
3	RCF Speaker	Mobile	1	PASS	0.19	>19.9 M Ω	0.56	PASS
4	RCF Speaker	Mobile	1	PASS	0.28	>19.9 M Ω	0.61	PASS
5	IEC Lead	Mobile	1	PASS	0.12	>19.9 M Ω	n/a	PASS
6	Starcloth Controller	Mobile	1	PASS	0.08	>19.9 M Ω	0.10	PASS
7	Powercon Lead	Mobile	1	PASS	0.12	>19.9 M Ω	n/a	PASS
8	Powercon Lead	Mobile	1	PASS	0.16	>19.9 M Ω	n/a	PASS
9	Pocket Pro Light	Mobile	1	PASS	0.12	>19.9 M Ω	0.10	PASS
10	Pocket Pro Light	Mobile	1	PASS	0.16	>19.9 M Ω	0.10	PASS
11	Powercon Lead	Mobile	1	PASS	0.18	>19.9 M Ω	n/a	PASS
12	Powercon Lead	Mobile	1	PASS	0.12	>19.9 M Ω	n/a	PASS
13	Pocket Pro Light	Mobile	1	PASS	0.17	>19.9 M Ω	0.63	PASS
14	Pocket Pro Light	Mobile	1	PASS	0.21	>19.9 M Ω	0.69	PASS
15	20m Extension	Mobile	1	PASS	0.38	>19.9 M Ω	n/a	PASS
16	IEC Lead	Mobile	1	PASS	0.06	>19.9 M Ω	n/a	PASS
17	Smoke Machine	Mobile	1	PASS	0.07	>19.9 M Ω	0.10	PASS
18	25m Extension	Mobile	1	PASS	0.45	>19.9 M Ω	n/a	PASS
19	20m Extension	Mobile	1	PASS	0.38	>19.9 M Ω	n/a	PASS

20	20m Extension	Mobile	1	PASS	0.45	>19.9 MΩ	n/a	PASS
21	Hardon Light	Mobile	1	PASS	0.12	>19.9 MΩ	0.10	PASS
22	Quad Phase	Mobile	1	PASS	0.11	>19.9 MΩ	0.10	PASS
23	Power Supply	Mobile	2	PASS	n/a	>19.9 MΩ	0.10	PASS
24	Power Supply	Mobile	2	PASS	n/a	>19.9 MΩ	0.10	PASS
25	6-Way Extension	Mobile	1	PASS	0.13	>19.9 MΩ	n/a	PASS
26	6-Way Extension	Mobile	1	PASS	0.12	>19.9 MΩ	n/a	PASS
27	5m Extension	Mobile	1	PASS	0.17	>19.9 MΩ	n/a	PASS
28	IEC Lead	Mobile	1	PASS	0.05	>19.9 MΩ	n/a	PASS
29	IEC Lead	Mobile	1	PASS	0.10	>19.9 MΩ	n/a	PASS
30	IEC Lead	Mobile	1	PASS	0.21	>19.9 MΩ	n/a	PASS
31	IEC Lead	Mobile	1	PASS	0.05	>19.9 MΩ	n/a	PASS
32	IEC Lead	Mobile	1	PASS	0.12	>19.9 MΩ	n/a	PASS
33	Hadron Light	Mobile	1	PASS	0.12	>19.9 MΩ	0.10	PASS
34	Mini Dekker Light	Mobile	1	PASS	0.14	>19.9 MΩ	0.10	PASS
35	Impossibled	Mobile	1	PASS	0.12	>19.9 MΩ	0.10	PASS
36	Blower	Mobile	2	PASS	n/a	>19.9 MΩ	0.10	PASS
37	Blower	Mobile	2	PASS	n/a	>19.9 MΩ	0.10	PASS
38	Blower	Mobile	2	PASS	n/a	>19.9 MΩ	0.10	PASS
39	8-Way Extension	Mobile	1	PASS	0.33	>19.9 MΩ	n/a	PASS
40	IEC Lead	Mobile	1	PASS	0.50	>19.9 MΩ	n/a	PASS
41	Power Supply	Mobile	2	PASS	n/a	>19.9 MΩ	0.10	PASS
42	Power Supply	Mobile	2	PASS	n/a	>19.9 MΩ	0.10	PASS
43	Blower	Mobile	1	PASS	0.16	>19.9 MΩ	0.10	PASS
44	Blower	Mobile	1	PASS	0.06	>19.9 MΩ	0.10	PASS
45	6-Way Extension	Mobile	1	PASS	0.18	>19.9 MΩ	n/a	PASS
46	IEC Lead	Mobile	1	PASS	0.27	>19.9 MΩ	n/a	PASS
47	IEC Lead	Mobile	1	PASS	0.48	>19.9 MΩ	n/a	PASS
48	IEC Lead	Mobile	1	PASS	0.32	>19.9 MΩ	n/a	PASS
49	6-Way Extension	Mobile	1	PASS	0.48	>19.9 MΩ	n/a	PASS
50	IEC Lead	Mobile	1	PASS	0.48	>19.9 MΩ	n/a	PASS
51	IEC Lead	Mobile	1	PASS	0.41	>19.9 MΩ	n/a	PASS
52	Printer	Mobile	1	PASS	0.11	>19.9 MΩ	0.46	PASS
53	Power Supply	Mobile	2	PASS	n/a	>19.9 MΩ	0.10	PASS
54	Power Supply	Mobile	2	PASS	n/a	>19.9 MΩ	0.10	PASS
55	Power Supply	Mobile	2	PASS	n/a	>19.9 MΩ	0.10	PASS
56	Power Supply	Mobile	2	PASS	n/a	>19.9 MΩ	0.10	PASS
57	8-Way Extension	Mobile	1	PASS	0.14	>19.9 MΩ	n/a	PASS